



CERTIFIKAT

No. 42 71 01

Document cabinets

Holder/Issued to/Manufacturer

Bayersystem Grzenia Sp.j., ul. Św. M. Kolbego 48, 85-433 Bydgoszcz, Poland

Product

Document cabinets

Product name

TG FIRE LINE

for details, see attached appendix

Product information

See attached appendix

Fire resistance class

NT FIRE 017 - 60 Paper

Performance specification

NT FIRE 017 and SP's certification rules for fire resisting storage cabinets, SPCR 002.

Marking

Marking in the cabinet shall show the name of the product, its fire resistance class, its serial number, the number of this certificate and SP's **P**-symbol.

Validity

This certificate is valid until not longer than 31st March, 2014.


Miscellaneous

The manufacturer's in-house inspection is under surveillance by SP in accordance with section 4 and 5 of SPCR 002. Other terms and conditions are set out in section 6 of SPCR 002. This is the second, extended, issue of this certificate, which was originally issued on 16th February 2006.

Borås, 5th June 2009

**SP Technical Research Institute of Sweden
Certification**


Lennart Månsson
Certification Manager


Lennart Aronsson
Certification Officer



1002
EN 45 011



Certificate issued by an Accredited Certification Body

SP Technical Research Institute of Sweden

Postal address	Phone / Fax	Reg. number	E-mail / Internet
SP Box 857 SE-501 15 Borås SWEDEN	+46 10 516 50 00 +46 33 13 55 02	556464-6874	info@sp.se www.sp.se

Swedish accredited certification bodies are appointed by SWEDAC, the Swedish Board for Accreditation and Conformity Assessment, under the terms of the Act. This certificate may not be reproduced other than in full, except with the prior written approval by SP.

Product information

Cabinet model	External dimensions (mm)			Internal dimensions (mm)			Weight (kg)
	width	height	depth	width	height	depth	
TG-FL1 TG-FL2	390	296	320	310	215	215	25
TG-FL3 TG-FL4	296	390	320	215	310	215	25
TG-FL5 TG-FL6	424	344	388	325	245	260	37
TG-FL7 TG-FL8	344	424	388	245	325	260	37
TG-FL9 TG-FL10	480	344	388	355	219	262	45
TG-FL11 TG-FL12	344	480	388	219	355	262	45
TG-FL15 TG-FL16	410	520	445	305	415	320	63



Handled by, department
Lennart Aronsson
Certification
+46 10 516 5241, lennart.aronsson@sp.se

Date
2009-06-22

Reference
Your reference
Katarzyna Kowalska

Page
1 (1)

Metalkas
ul.Deszczowa 63
PL-85-467 BYDGOSZCZ
Polen

Certificate

Enclosed please find a revised certificate. The validity is now extended with another five years. The holder is also changed from Metalkas to Bayersystem.

The certificates give you the right to put SPs **P**-mark on the products which are covered by the certificates and fulfils the requirements in SP's *Certification rules for fire resisting storage cabinets, SPCR 002*, http://www.sp.se/cert/cert_prod/spcr/spcr002.pdf.

The validity of the individual certificate is presuming that the production control is effective and prevent non-conforming cabinets to be marked with the **P**-mark and that the other conditions in SPCR 002 are met. For this certificate the validity is also presuming that certificate no. 38 27 01, holder Sun Safe Mfg. Co., is valid.

Yours sincerely,

**SP Technical Research Institute of Sweden
Certification**



Lennart Aronsson

Appendix

Certificate no. 42 71 01

Copy (pdf)

Joel Blom, SP
Seok Sun Yun, Sun Safe Mfg Co.

SP Technical Research Institute of Sweden

A Member of United Competence

Postal address	Office location	Telephone / Telefax	E-mail / Internet	Bank	PlusGiro	Reg.number
SP Box 857 SE-501 15 Borås SWEDEN	Västeråsen Brinellgatan 4 SE-504 62 Borås	+46 10 516 50 00 +46 33 13 55 02	info@sp.se www.sp.se	715-1053	10 55-3	556464-6874