



CERTIFIKAT

No. 42 71 03

Document cabinets – Fire Line Plus

Holder/Issued to/Manufacturer

Metalkas, ul.Deszczowa 63, PL-85-467 BYDGOSZCZ, Poland

Product

Document cabinets

Product name

See attached appendix

Product information

See attached appendix

Fire resistance class

NT FIRE 017 - 120 Paper

Performance specification

NT FIRE 017 and SP's certification rules for fire resisting storage cabinets, SPCR 002.

Marking

Marking in the cabinet shall show the name of the product, its fire resistance class, its serial number, the number of this certificate and SP's P-symbol.

Validity

This certificate is valid until not longer than 31st July 2011.

Miscellaneous

The manufacturer's in-house inspection is under surveillance by SP in accordance with section 4 and 5 of SPCR 002. Other terms and conditions are set out in section 6 of SPCR 002. This is the first issue of this certificate.

Borås, 15th August 2007

**SP Technical Research Institute of Sweden
Certification**


Lennart Månsson
Certification Manager


Lennart Aronsson
Certification Officer

Certificate issued by an Accredited Certification Body

SP Technical Research Institute of Sweden

Postal address Phone/Fax Reg.number E-mail/Internet
SP +46 10 516 50 00 556464-6674 info@sp.se
Box 857 +46 33 13 55 02 www.sp.se
SE-501 15 Borås
SWEDEN

Swedish accredited certification bodies are appointed by SWEDAC, the Swedish Board for Accreditation and Conformity Assessment, under the terms of the Act. This certificate may not be reproduced other than in full, except with the prior written approval by SP.

